



Republic of the Philippines
Department of Agriculture

SUGAR REGULATORY ADMINISTRATION

Sugar Center Bldg., North Avenue, Diliman, Quezon City, Philippines 1101

TIN 000-784-336

Website: <http://www.sra.gov.ph>

Email Address: srahead@sra.gov.ph

Tel No. (632) 8929-3633, (632) 3455-2135, (632) 3455-3376

SUGAR REGULATORY ADMINISTRATION

North Avenue., Diliman, Quezon City

BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL BID BULLETIN NO. 1

This **Supplemental Bid Bulletin No. 1** dated **03 July 2024** is issued to inform the prospective bidders of the following amendments, modifications and clarifications on the items in the Philippine Bidding Documents (PBDs) for the **SUPPLY OF LABOR, MATERIALS, AND EQUIPMENT FOR THE PROJECT "RETROFITTING OF SUGAR REGULATORY ADMINISTRATION (SRA) MAIN AND ANNEX 1 BUILDING"** as previously posted in the Philippine Government Electronic Procurement System (PhilGEPS) and the Sugar Regulatory Administration (SRA) website. This Supplemental Bid Bulletin shall form an integral part of the Bidding Documents.

| ORIGINAL BID DOCUMENT | | CLARIFICATIONS/CORRECTIONS /CHANGES | |
|------------------------------------|---|--|--|
| <i>Section III. Bid Data Sheet</i> | | <i>Section III. Bid Data Sheet</i> | |
| Bid Data Sheet | | Bid Data Sheet | |
| ITB Clause | | ITB Clause | |
| 5.2 | For this purpose, contracts similar to the Project refer to contracts which have the same major categories of work, which shall be: Structural Retrofitting of building. | 5.2 | For this purpose, contracts similar to the Project refer to contracts which have the same major categories of work, which shall be: Structural Retrofitting of building <u>and/or</u> bridges. |
| 10.3 | Philippine Contractors Accreditation Board (PCAB) License Category – A (minimum) Size Range – Medium A | 10.3 | Philippine Contractors Accreditation Board (PCAB) License Category – A (minimum) Size Range – Medium A |
| 10.4 | The key personnel must meet the required minimum years of experience set below: <u>Key Personnel</u> <u>General Experience</u> <u>Relevant Experience</u> Project Manager, Project/Site Engineer, Materials Engineer, Safety Officer, Construction Foreman, Skilled Workers, Laborers With at least 10 years work experience in building construction. | 10.4 | The key personnel must meet the required minimum years of experience set below: <u>Key Personnel</u> <u>General Experience</u> <u>Relevant Experience</u> <u>Project Manager</u> With at least 10 years work experience in <u>retrofitting of building and/or bridges.</u> |
| 10.5 | The minimum major equipment requirements are the following: <u>Equipment</u> <u>Capacity</u> <u>Number of Units</u> Crane or boom truck, Power Tools, Welding Machine, Oxy Acetylene with cutting outfit, Jack Hammer, Steel Scaffolding and all/any other equipment needed to complete/finish the project. | 10.5 | The minimum major equipment requirements are the following: <u>Equipment</u> <u>Capacity</u> <u>Number of Units</u> <u>Boom truck</u> , Power Tools, Welding Machine, Oxy Acetylene with cutting outfit, Jack Hammer, Steel Scaffolding and all/any other equipment needed to complete/finish the project. |



| | |
|--|---|
| <p style="text-align: center;">Section VI. Specifications TECHNICAL SPECIFICATIONS SECTION 1 GENERAL REQUIREMENTS</p> <p>PART 2 – PRODUCTS</p> <p>2.1 UTILITIES</p> <p>A. Temporary Utilities</p> <p>1. General Water and electricity required for the performance of the work shall be provided by SRA.</p> <p>2. Water Furnish and install all necessary temporary piping, and upon completion of the work, remove all such temporary piping.</p> <p>3. Temporary Electricity Furnish and install all necessary temporary wiring for power and lighting, and upon completion of the work, remove all such temporary wiring.</p> <p>4. Telephone Maintain in the job office a telephone for the use of the Engineer</p> <p>2.2 FIELD OFFICE SHEDS Furnish and install site office adequate in size and accommodation for all Contractor's offices, Project Manager's office, supply and tool room; make the field office available to the Owner/representative, the Engineer and the Construction Manager throughout the entire construction period. Provide an adequate watertight office with water, light, telephone and toilet facilities.</p> <p>2.3 SANITARY FACILITIES Furnish and install all required temporary toilets with sanitary toilets for use of all workmen, comply with all minimum requirements of the Health Department or other public agency having jurisdiction, maintain in a sanitary condition at all times. Provide and install toilet facilities for the exclusive use of the Construction Manager.</p> <p>2.4 STORAGE FACILITIES Provide storage facilities.</p> <p>2.5 ENCLOSURES Furnish and install, and maintain for the duration of construction all required scaffolds, tarpaulins, barricades, warning signs, steps, bridges, platforms, and other temporary construction necessary for proper completion of the work in the compliance with all pertinent safety and other regulations.</p> | <p style="text-align: center;">Section VI. Specifications TECHNICAL SPECIFICATIONS SECTION 1 GENERAL REQUIREMENTS</p> <p>PART 2 – PRODUCTS</p> <p>2.1 UTILITIES</p> <p>A. Temporary Utilities</p> <p>1. General <u>Except for the site office</u>, water and electricity required for the performance of the work shall be provided by SRA.</p> <p>2. Water Furnish and install all necessary temporary piping, and upon completion of the work, remove all such temporary piping.</p> <p>3. Temporary Electricity Furnish and install all necessary temporary wiring for power and lighting, and upon completion of the work, remove all such temporary wiring.</p> <p>4. Telephone Maintain in the job office a telephone for the use of the Engineer</p> <p>2.2 FIELD OFFICE SHEDS Furnish and install site office adequate in size and accommodation for all Contractor's offices, Project Manager's office, supply and tool room; make the field office available to the Owner/representative, the Engineer and the Construction Manager throughout the entire construction period. Provide an adequate watertight office with water, light, telephone and toilet facilities.</p> <p>2.3 STORAGE FACILITIES <u>SRA shall designate the area for the storage facilities to be provided by the contractor.</u></p> <p>2.4 ENCLOSURES Furnish and install, and maintain for the duration of construction all required scaffolds, tarpaulins, barricades, warning signs, steps, bridges, platforms, and other temporary construction necessary for proper completion of the work in the compliance with all pertinent safety and other regulations.</p> |
| <p style="text-align: center;">SECTION 2 CARBON FIBER SHEET</p> <p>2.3.5 APPLICATION OF EPOXY RESIN FOR UNDERCOAT (PENETRATING/ IMPREGNATION EPOXY RESIN)</p> <p>Prior to undercoating epoxy resin adhesive, ambient temperature at the work site shall be checked to confirm the curing conditions before applying the resin. The Contractor shall check and confirm that the primer and putty have become tack-free and there is no clay and dust on the concrete surface prior to the Engineer's inspection. If there is a time interval of longer than 3 days after the primer and putty application, the primer and putty coated surface should be roughened with sandpaper, and the surface cleaned before the adhesive application.</p> <p>The contact surface condition shall be tack-free and application shall not be done during rains or storms or when the air is misty, or when in the opinion of the Engineer, Conditions are unsatisfactory to carry out the work. The following specified quantity of the resin is only reference. The actual quantity should be determined in consideration with ambient temperature and manufacturer's recommendation in the work site, subject to the Engineer's approval.</p> | <p style="text-align: center;">SECTION 2 CARBON FIBER SHEET</p> <p>2.3.5 APPLICATION OF EPOXY RESIN FOR UNDERCOAT (PENETRATING/ IMPREGNATION EPOXY RESIN)</p> <p>Prior to undercoating epoxy resin adhesive, ambient temperature at the work site shall be checked to confirm the curing conditions before applying the resin. The Contractor shall check and confirm that the primer and putty have become tack-free and there is no clay and dust on the concrete surface prior to the Engineer's inspection. If there is a time interval of longer than 3 days after the primer and putty application, the primer and putty coated surface should be roughened with sandpaper, and the surface cleaned before the adhesive application.</p> <p>The contact surface condition shall be tack-free and application shall not be done during rains or storms or when the air is misty, or when in the opinion of the Engineer, Conditions are unsatisfactory to carry out the work. The following specified quantity of the resin is only reference. The actual quantity should be determined in consideration with ambient temperature and manufacturer's recommendation in the work site, subject to the Engineer's approval.</p> |



The mixing and application of the adhesive resin (resin and handener) should be in accordance with the manufacturer's instruction approved by the Engineer.

NOTE:

- All equipment, supplies and materials must be brand new and to be delivered at Sugar Regulatory Administration, North Avenue, Diliman, Quezon City, at the expense of the contractor.

The mixing and application of the adhesive resin (resin and hardener) should be in accordance with the manufacturer's instruction approved by the Engineer.

NOTE:

- All supplies and materials must be brand new and to be delivered at Sugar Regulatory Administration, North Avenue, Diliman, Quezon City, at the expense of the contractor.

Section VIII. Bill of Quantities

PROJECT

LOCATION

DATE

NORTH AVENUE,
: DILIMAN, QUEZON
CITY
: JANUARY
4, 2024

| ITEM | DESCRIPTION | QTY. | UNIT | UNIT COST | | TOTAL COST |
|------------------------------------|---|------|------|-----------|--------------|------------|
| | | | | Materials | Labor & Cons | |
| MAIN BUILDING | | | | | | |
| I. | GENERAL REQUIREMENTS | | | | | |
| 1 | Permits & Licenses (Building, Mechanical, Electrical , Locational, Sanitary, Occupancy etc.) | 1.00 | lot | | | |
| 2 | Bonds & Insurances (Performance, Surety, CARL, Warranty) | 1.00 | lot | | | |
| 3 | Mobilization and Demobilization | 1.00 | lot | | | |
| 4 | Temfacil/ Field Office/ Warehouse | 1.00 | lot | | | |
| 6 | As-Built Drawings | 1.00 | lot | | | |
| TOTAL ITEM I. GENERAL REQUIREMENTS | | | | | | |

| ITEM | DESCRIPTION | QTY. | UNIT | UNIT COST | | TOTAL COST |
|------------------------------------|---|------|------|-----------|--------------|------------|
| | | | | Materials | Labor & Cons | |
| ANNEX BUILDING II | | | | | | |
| I. | GENERAL REQUIREMENTS | | | | | |
| 1 | Permits & Licenses (Building, Mechanical, Electrical , Locational, Sanitary, Occupancy etc.) | 1.00 | lot | | | |
| 2 | Bonds & Insurances (Performance, Surety, CARI, Warranty) | 1.00 | lot | | | |
| 3 | Mobilization and Demobilization | 1.00 | lot | | | |
| 4 | Temfacil/ Field Office/ Warehouse | 1.00 | lot | | | |
| 6 | As-Built Drawings | 1.00 | lot | | | |
| TOTAL ITEM I. GENERAL REQUIREMENTS | | | | | | - |

Section VIII. Bill of Quantities

PROJECT

LOCATION

DATE

NORTH AVENUE,
: DILIMAN, QUEZON
CITY
: JANUARY
4, 2024

| ITEM | DESCRIPTION | QTY. | UNIT | UNIT COST | | TOTAL COST |
|---------------|--|------|------|-----------|--------------|------------|
| | | | | Materials | Labor & Cons | |
| MAIN BUILDING | | | | | | |
| I. | GENERAL REQUIREMENTS | | | | | |
| 1 | Permits & Licenses (Building, Mechanical, Electrical , Locational, Sanitary, Occupancy, <u>Safety and Health Program, Material Testing</u>) | 1.00 | lot | | | |
| 2 | Bonds & Insurances (Performance, Surety, CARL, Warranty) | 1.00 | lot | | | |
| 3 | Mobilization and Demobilization | 1.00 | lot | | | |
| 4 | Temfacil/ Field Office/ Warehouse | 1.00 | lot | | | |
| 6 | As-Built Drawings | 1.00 | lot | | | |
| | TOTAL ITEM I. GENERAL REQUIREMENTS | | | | | |

| ITEM | DESCRIPTION | QTY. | UNIT | UNIT COST | | TOTAL COST |
|------------------------------------|--|------|------|-----------|--------------|------------|
| | | | | Materials | Labor & Cons | |
| ANNEX BUILDING I | | | | | | |
| I. | GENERAL REQUIREMENTS | | | | | |
| 1 | Permits & Licenses (Building, Mechanical, Electrical , Locational, Sanitary, Occupancy, <u>Safety and Health Program, Material Testing</u>) | 1.00 | lot | | | |
| 2 | Bonds & Insurances (Performance, Surety, CARL, Warranty) | 1.00 | lot | | | |
| 3 | Mobilization and Demobilization | 1.00 | lot | | | |
| 4 | Temfacil/ Field Office/ Warehouse | 1.00 | lot | | | |
| 6 | As-Built Drawings | 1.00 | lot | | | |
| TOTAL ITEM I. GENERAL REQUIREMENTS | | | | | | |

Prepared by:

ATTY. JEANELLE V. TAMORO-CRUZ
Head, BAC Secretariat

Approved by:

ATTY. RONALD E. RIMANDO
Chairperson, Bids and Awards Committee



Management
System
ISO 9001:2015
www.tuv.com
ID 9105085567

